


NOTES: ADEQUATE STRUCTURAL SUPPORTS AND THE NUMBER AND TYPE OF FASTENERS REQUIRED TO COMPLY WITH APPLICABLE CODES, SHOULD BE DETERMINED AND VERIFIED BY PROJECT ARCHITECT/ENGINEER.

ADDITIONAL REINFORCING (MM 6125 W/6" WIDE FLEX-FLASH F) IS REQUIRED OVER SUBSTRATE BOARD JOINTS FOR EXTENDED (10+ YEARS) WARRANTIES. (SEE INSET DETAIL)

THE FR (FABRIC REINFORCED) MEMBRANE ASSEMBLY IS ALSO REQUIRED IN ANY REHAB/RETROFIT APPLICATION AND MAY ALSO BE USED ON NEW CONCRETE.



Monolithic Membrane
6125-FR
ROOFING SYSTEMS

AMERICAN HYDROTECH, INC.

ALTERNATE SUBSTRATE APPLICATIONS	
3"=1'-0"	R-5A