



NOTES: IN COVERED/BURIED CONDITIONS, MM 6125 IS EXTENDED AS CONTINUOUS FLASHING AS HIGH AS POSSIBLE. FLASHING MUST BE TERMINATED NO LESS THAN 4" ABOVE SUBSTRATE.

REGLETS CAN BE CAST/FORMED OR CUT INTO THE CONCRETE. REGLETS SHOULD BE MIN. 1/2" DEEP AND PROVIDE AN EASY TRANSITION FOR THE MEMBRANE FLASHING.

ADDITIONAL REINFORCEMENT NOT REQUIRED AT TYPICAL CONSTRUCTION/CONTROL JOINTS WITH THE FR (FABRIC REINFORCED) MEMBRANE ASSEMBLY.



Monolithic  
Membrane  
6125-FR  
WATERPROOFING SYSTEMS

AMERICAN HYDROTECH, INC.

CONCRETE CONSTRUCTION JOINTS

3"=1'-0"

W-4