



NOTES:

1. IF STYROFOAM INSULATION IS USED, IT MUST BE 60 PSI (COMPRESSIVE STRENGTH) BOARD MINIMUM.
2. THE PEDESTAL SHOWN IS 1/2 A TYPICAL UNIT, WITH THE TRANSVERSE SPACER LUGS LEFT INTACT TO MAINTAIN THE APPROPRIATE JOINT SPACE AT TERMINATION.
3. MINOR LEVEL ADJUSTMENTS CAN BE MADE BY PLACING SHIMS UNDERNEATH THE PEDESTAL. SHIMS PLACED ON TOP OF THE PEDESTAL MUST NOT EXCEED THE HEIGHT OF THE SPACER LUGS.
4. REFER TO APPLICABLE MM6125-FR ROOFING OR WATERPROOFING GUIDELINE DETAILS FOR PROPER MEMBRANE/FLASHING DETAILS AND ALTERNATIVES



**ULTIMATE
ASSEMBLY**

AMERICAN HYDROTECH, INC.

**TYPICAL TERMINATION
AT WALL/PARAPET/CURB**

**SCALE: NONE
DATE: 11/06/20**

UA-1